CURB AND GUTTER

PLUG TAPPED 2"

WATER MAIN

B

D

A

A

F

4" MAX.

SIDEWALK

DRAIN HOLE

C

BRASS ELBOW

E

2" ø GALVANIZED STAND PIPE (SOLID PIECE)
THREADED BOTH ENDS – STAND PIPE
SHALL BE A MAX. OF 4" FROM LID (THREADED)
BUT SHALL NOT INTERFERE WITH
SEATING OF LID

LEGEND

	DESCRIPTION
A	CAST IRON VALVE BOX W/ LID. (SEE STANDARD DETAIL FIGURE 5)
B	2" GATE VALVE WITH 2" OPERATING NUT
C	CONCRETE THRUST BLOCK
D	2" X 6" BRASS NIPPLE (MINIMUM 6" LENGTH)
E	2" X 6" GALVANIZED NIPPLE (MINIMUM 6" LENGTH)
F	2" PLASTIC CAP HAND TIGHT ONLY TO PROTECT THREADS